

**RIVERSIDE COUNTY FLOOD CONTROL &
WATER CONSERVATION DISTRICT**

**REQUEST FOR BID NO. FCARC-00163
WHITTIER AVENUE CHANNEL INVERT REPAIR AT KIRBY STREET, HEMET**



**ADDENDUM NO. 1
March 21, 2020**

Marilyn Weisenberg, Administrative Services Analyst II
Purchasing Supervisor
Riverside County Flood Control &
Water Conservation District
1995 Market Street
Riverside, CA 92501
mweisen@rivco.org
951-955-4348

ADDENDUM NO. 1
TO RFB #FCARC-00163

1.0 This addendum is considered to be part of the RFB. All other terms of the RFB remain unchanged and in effect. This addendum is intended to provide additional information and/or to change requirements in the above referenced RFB. Any information contained herein will be considered part of the RFB and as such will be used in the evaluation of the bid responses. Attention all potential bidders, if you have already submitted your proposal prior to the bid closing date, please review this addendum and re-submit your bid response, should this addendum modify your initial bid response.

2.0 Respond to the RFB at:

Riverside County Flood Control
and Water Conservation District
Attention: Marilyn Weisenberg
RFB # FCARC-00163
1995 Market Street, Riverside, CA, 92501

All bids must be submitted on the Bid Form (pages 6 through 12). The bid shall be delivered (no email delivery) to the District at the address stated above on or before 1:30 p.m. on the closing date. The RFB number, title, and closing date and time shall appear on both the envelope and the bid cover sheet. Under no circumstances will a bid be accepted after the closing date and time.

3.0 Questions and Facts from the Mandatory Pre-Bid Meeting:

- Will the County allow more than 20 working days if needed?
 - a. **Extensions would be considered on a case by case basis. The District will accommodate schedule changes within reason.**
- Please clarify the type of equipment allowed on the concrete invert.
 - a. **Section 8.12 of the specs covers Use of the Channel Invert and has a list of allowed equipment.**
- Is any lane closure allowed?
 - a. **Yes, City of Hemet will accept closing a lane per an approved traffic control plan prior to the start of construction. The traffic control plan shall also show any sidewalk closures.**
- The project must have a concrete washout station. Please refer to the Pollution Prevention Plan (WM-8 – Concrete Waste Management).
- The City requests start time after 7am.
- The new concrete will be keyed into the existing concrete. No doweling.
- The District will work to clean any homeless camps under the bridge prior to the start of work.
- Confirmed the link under Public Notices and Non-Construction Bids are both working and have the corrected links.
- An encroachment permit will be required for the approved traffic control plan.

4.0 List of contractors that attended the Mandatory Pre-Bid Meeting:

- a. GRFCO, Inc.
- b. Hillcrest
- c. KIP, Inc
- d. Leonida Builders, Inc
- e. Scorpion Backhoe, Inc
- f. Southwest General Engineering, Inc
- g. Jeremy Harris Construction, Inc