

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

Riverside County Flood Control
and Water Conservation District

Board of Supervisors

**RESOLUTION NO. F2015-36
SETTING A PUBLIC HEARING DATE FOR
BANNING MASTER DRAINAGE PLAN LINE H, STAGE 1 PROJECT
IN ACCORDANCE WITH SECTION 18 OF THE
RIVERSIDE COUNTY FLOOD CONTROL AND
WATER CONSERVATION DISTRICT ACT**

WHEREAS, Act 6642 of the State Legislature, Section 18 of the Riverside County Flood Control and Water Conservation District Act ("District Act") requires that the Riverside County Flood Control and Water Conservation District ("District") give public notice and conduct a public hearing prior to undertaking construction of District facilities; and

WHEREAS, this Board of Supervisors ("Board") intends to undertake a project within the city of Banning designated as the Banning Master Drainage Plan (MDP) Line H, Stage 1 Project ("Project"); and

WHEREAS, the Project is generally bounded to the south by Porter Street, to the west by South Hargrave Street, to the north by Interstate 10, and to the east by the City of Banning Water Reclamation Facility; and

WHEREAS, the Project consists of the construction, operation and maintenance of an underground storm drain system and an outlet within Smith Creek which is designed to provide 100-year flood protection; and

WHEREAS, the Section 18 Map, dated November 2015, bearing the name and showing the general location and typical cross sections of the Project (Attachment "A") is on file with the Clerk of the Board; and

WHEREAS, the engineering cost estimate of the Project, entitled "Engineer's Statement" (Attachment "B") is on file with the Clerk of the Board; and

FORM APPROVED COUNTY COUNSEL
MICHELLE CLACK
11/20/15
DATE

1 **WHEREAS**, in accordance with the California Environmental Quality Act (CEQA), the
2 District prepared an Initial Study which demonstrates that, with the incorporation of required
3 mitigation, the Project will not have a significant effect on the environment and, therefore, a
4 Mitigated Negative Declaration (MND) is proposed; and

5
6 **WHEREAS**, the Initial Study and MND (SCH No. 2015061074) were circulated for a 30-
7 day public review period pursuant to CEQA beginning on June 30, 2015; and

8 **WHEREAS**, on December 15, 2015, the date of the Section 18 Public Hearing, the Board
9 will consider the MND under Resolution No. F2015-37; and

10 **WHEREAS**, the Section 18 map and the Engineer's Statement for the Project are posted
11 on the District's website at <http://rcflood.org> under the CEQA/Section 18 tab and may be inspected
12 at the District's office located at 1995 Market Street, Riverside, California 92501 or at Banning
13 City Hall located at 99 East Ramsey Street, Banning, California 92220; and

14
15 **WHEREAS**, pursuant to Section 18 of the District Act, prior to making a decision on the
16 Project, this Board will consider all written and oral comments; and

17 **WHEREAS**, pursuant to Section 18 of the District Act, any person wishing to comment
18 on the Project may do so in writing between the date of this notice and the public hearing, or may
19 appear and be heard at the time and place noted below.

20
21 **NOW, THEREFORE, BE IT RESOLVED, DETERMINED AND ORDERED** by the
22 Board of Supervisors of the Riverside County Flood Control and Water Conservation District in
23 regular session assembled on November 3, 2015 that:

24 1. A public hearing pertaining to the Banning MDP Line H, Stage 1 Project will be held
25 in accordance with Section 18 of the District Act on December 15, 2015 at 10:30 a.m., or as soon
26 as possible thereafter, at the meeting room of this Board, 1st Floor, County Administrative Center,
27 4080 Lemon Street, Riverside, California, 92501 at which time all public comments shall be heard.
28

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

2. The District shall cause a copy of this Resolution and copies of the Section 18 Map and Engineer's Statement to be posted at least 21 days before said hearing at Banning City Hall located at 99 East Ramsey Street, Banning, California 92220.

3. The District shall cause a copy of this resolution and copies of the Section 18 Map and Engineer's Statement to be posted at least 21 days before said hearing at the Riverside County Flood Control and Water Conservation District located at 1995 Market Street, Riverside, California 92501.


4. The District shall cause a copy of this resolution to be posted at least 21 days before said hearing at the Riverside County Clerk and Recorder's Office, 2724 Gateway Drive, Riverside, California 92507.

5. The Clerk of this Board is directed to cause a copy of this resolution to be published twice, once at least 21 days before said hearing and once 7 days following the initial publication, in a newspaper of general circulation in accordance with Section 18 of the District Act.

ROLL CALL:

Ayes: Jeffries, Tavaglione, Washington, Benoit and Ashley
Nays: None
Absent: None

The foregoing is certified to be a true copy of a resolution duly adopted by said Board of Supervisors on the date therein set forth.

KECIA HARPER-IHEM, Clerk of said Board
By  Deputy

Attachment "A"



Source: Esri, DigitalGlobe, GeoEye, i-cubed, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AEX, Getmapping, Aerogrid, IGN, IGP, swisstopo, and the GIS User Community

RIVERSIDE COUNTY FLOOD CONTROL
AND WATER CONSERVATION DISTRICT

Section 18 Map
Banning MDP Line H, Stage 1
Project No. 5-0-00177-01

November 2015

Legend

 Storm Drain Alignment



NTS

ATTACHMENT "B"

**Banning Master Drainage Plan Line H, Stage 1
Project No. 5-0-00177-01
Engineer's Statement**

The proposed Banning Master Drainage Plan (MDP) Line H, Stage 1 project is generally located along South Hathaway Street, south of Interstate 10, in the city of Banning in Riverside County, California. The project is a proposed facility of the District's Banning MDP. The drain is being designed to convey 100-year storm flows rather than the 10-year proposed in the MDP. The project will convey flows to Smith Creek, which is primarily a natural wash, except for some concrete slope protection to protect the west bank of the creek.

The underground storm drain would be constructed along Hathaway Street, beginning at Barbour Street and extending approximately 0.5 mile south to Wesley Street and then continue east along Wesley Street for approximately 0.25 mile to Smith Creek.

The storm drain system is comprised of approximately 200 feet of 7-foot wide by 4-foot high reinforced concrete box and approximately 4,000 feet of reinforced concrete pipe ranging in size from 30 inches to 72 inches in diameter. A wing wall outlet structure and riprap apron would be constructed at the storm drain outlet proposed at Smith Creek.

The estimated cost of the project is \$2,800,000.