

CONNECTOR PIPE COLLAR NTS

NOTES

- ① CONCRETE SHALL BE CLASS "B" CONCRETE.
- 2 1/2" PREFORMED BITUMINOUS JOINT MATERIAL.
- (3) 2' WITH MIN. 6" BELOW GRADE OR AS DIRECTED BY ENGINEER.
- 4 PIPE COLLAR TO BE PLACED 2'INSIDE DISTRICT FENCE OR AS DIRECTED BY THE ENGINEER.



RIVERSIDE COUNTY FLOOD CONTROL

WATER CONSERVATION DISTRICT

APPROVED BY:

CHIEF ENGINEER

DATE: Dec. 18, 2003

R.C.E. NO. 32336

CONNECTOR PIPE COLLAR

STANDARD DRAWING NUMBER M821