



CUT CIRCULAR OPENING IN SRP AND REAPPLY ZINC GALVANIZATION TO EXPOSED EDGES. SRP STUB ANGLE PER PLAN.

SRP

PREFABRICATED SADDLE

7/16" DIA. BOLTS AT 6" O.C. ALL ROUND

1/8" TYP.

6" TYP.

2"

3"

SRP STUB

FILL ANNULAR SPACE WITH MASTIC SEALANT FOR SRP TO JOIN RCP.

Q LATERAL

RCP LATERAL

IF CONNECTING TO RCP SRP TO BE 6" DIA. GREATER THAN RCP. FOR SRP JOIN, CONNECT WITH STANDARD COUPLER BAND.

BUTYL RUBBER BETWEEN SRP AND PREFABRICATED SADDLE



RIVERSIDE COUNTY FLOOD CONTROL AND WATER CONSERVATION DISTRICT

APPROVED BY: *Warren D. Willams*

CHIEF ENGINEER

DATE: April 5, 2004

SPIRAL RIB PIPE SADDLE BRANCH JUNCTION

STANDARD DRAWING NUMBER M824

R.C.E. NO. 32336