



DETAIL "A"

N.T.S.

PIPE AND INVERT PAVING DETAIL

NOTES

NO SCALE

1. CONCRETE shall be 3000 psi at 28 days.
2. A MECHANICAL FINISHING process shall be used to produce profile and finish in one pass.
3. PROTECTIVE COATINGS
 - (A) EXTERIOR COATINGS. 25 mils of cold-applied mastic material that complies to AASHTO designation M-243.
 - (B) Installation of lifting lugs and steel reinforcement shall be accomplished prior to application of coating material.
4. CONCRETE INVERT shall be installed after completion of backfill operation in conformance with subsection 207-11.5.3. of the standard specifications.



RIVERSIDE COUNTY FLOOD CONTROL AND WATER CONSERVATION DISTRICT
 APPROVED BY: *Warren D. Williams*
 CHIEF ENGINEER
 DATE: April 5, 2004

SPIRAL RIB PIPE INVERT PAVING
 STANDARD DRAWING NUMBER M823